

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3240-1477:125 Page 1 of 1

CATEGORY: Duct Smoke Detector Housing/Base

LISTEE: Mircom Technologies Ltd., *25 Interchange Way, Vaughan, Ontario, Canada L4K 5W3
Contact: Mara Cherubin (905) 660-4655 FAX (905) 660-4113

DESIGN: Models MIX-DH200PL and MIX-DH200RPL duct smoke detector units. Unit consists of a housing, relay, electrical components, sampling and exhaust tubes and a listed detector head. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instruction, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, air velocity rating, and UL label.

APPROVAL: Listed as duct detector units when used with listee's separately listed compatible fire alarm control units. Intended for use in HVAC systems having air velocities between 100-4000 ft/min. Also, suitable for use as a stand alone unit where permitted. Refer to listee's Installation Instruction Manual for details.

XLF: 3240-1209:155

*Rev. 11-04-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**